

**Annual Drinking Water Quality Report**

**CLIFTON**

**IL0750250**

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CLIFTON is Ground Water

For more information regarding this report contact:

Name DEAN HARTMAN

Phone (815) 954-1822

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p>
<p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> <li>- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.</li> <li>- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.</li> <li>- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.</li> <li>- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.</li> <li>- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.</li> </ul>

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk.

Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact DEAN HARTMAN @ (815) 954-1822. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

## Source Water Information

Source Water Name		Type of Water	Report Status	Location
WELL 1 (47548)	NORTH WELL INSIDE PLANT	GW	_____	_____
WELL 3 (01449)	LEAD WELL	GW	_____	N OF PLANT AT E 2ND AND S 1ST
WELL 4 (01864)		GW	_____	_____

## Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at (815) 954-1822. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: CLIFTON To determine Clifton's susceptibility to groundwater contamination, a Well Site Survey, published in 1995 by the Illinois EPA, and Source Water Protection Plan were reviewed. Based on the information contained in these documents, nineteen potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Clifton community water supply wells. These include eight below ground fuel storages, auto repair, two autobodies, a machine shop/shed, a grain elevator, a fertilizer warehouse, an implement sales/service, a construction/demolition co., a pesticide/fertilizer application or warehouse, an above ground fuel storage, and a fertilizer anhydrous storage. Based upon this information, the Illinois EPA has determined that Clifton Wells #1 and #2 are not susceptible to IOC, VOC, or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells. In anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that Clifton's community water supply wells are not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; there is a hydrogeologic barrier that restricts pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. However, having stated this, the U.S. EPA is proposing to require States to identify systems in karst, gravel and fractured rock aquifer systems as sensitive. Water systems utilizing these aquifer types would be required to perform routine source water monitoring. Because the community's wells are constructed in a confined aquifer, which should provide an adequate degree of protection to prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the vulnerability determination.

**Lead and Copper**

Definitions:  
 Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.  
 Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: 190 ug/L to 1300 ug/L  
 Lead Range: <1.0 ug/L to 2.4 ug/L

To obtain a copy of the system's lead tap sampling data: Call Deaan Hartman PH. (815) 954-1822

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.  
 To obtain a copy of the system's service line inventory: go to cliftonillinois.com and click on "RESOURCES", then scroll down and click the "Lead serv line Inventory" tab on lower left. This will download the file. Hover over the downloaded file and click on the box with the arrow in it to open with Microsoft Excel.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	07/31/2024	1.3	1.3	1.2	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	07/31/2024	0	15	1.2	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

## Water Quality Test Results

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

<b>Disinfectants and Disinfection By-Products</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Chlorine</b>	2025	1.4	0.75 - 1.71	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
<b>Haloacetic Acids (HAA5)</b>	2025	19	19.3 - 19.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
<b>Total Trihalomethanes (TTHM)</b>	2025	35	34.6 - 34.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
<b>Inorganic Contaminants</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Barium</b>	05/08/2024	0.039	0.039 - 0.039	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Fluoride</b>	2025	0.625	0.625 - 0.625	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Iron</b>	05/08/2024	0.072	0.072 - 0.072		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
<b>Manganese</b>	05/08/2024	5.3	5.3 - 5.3	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
<b>Nitrate [measured as Nitrogen]</b>	2025	2	1.7 - 1.7	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
<b>Sodium</b>	05/08/2024	52	52 - 52			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	01/07/2020	5.06	5.06 - 5.06	0	15	pCi/L	N	Erosion of natural deposits.

## Violations Table

### 2,4,5-TP (Silvex)

Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### 2,4-D

Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver,

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Alachlor

Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Aldrin

Some people who drink water containing excessive aldrin over a long period of time may experience problems with their liver, nervous system, weakened immune

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

### Atrazine

Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Benzo(a)pyrene

Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Carbofuran

Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Chlordane

Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

### Dalapon

Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Di (2-ethylhexyl) adipate

Some people who drink water containing di (2-ethylhexyl) adipate well in excess of the MCL over many years could experience general toxic effects or

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Di (2-ethylhexyl) phthalate

Some people who drink water containing di (2-ethylhexyl) phthalate in excess of the MCL over many years may have problems with their liver, or experience

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Dibromochloropropane (DBCP)

Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

---

### Dieldrin

---

Some people who drink water containing excessive Dieldrin over a long period of time may experience problems with their liver, nervous system, weakened

---

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

---

---

### Dinoseb

---

Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

---

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

---

---

### Diquat

---

Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.

---

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

---

---

### Endothall

---

Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

---

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

---

## Violations Table

### Endrin

Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Ethylene dibromide

Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach,

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Heptachlor

Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Heptachlor epoxide

Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

### Hexachlorobenzene

Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Hexachlorocyclopentadiene

Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Lindane

Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Methoxychlor

Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

### Oxamyl [Vydate]

Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### PCBs [Polychlorinated biphenyls]

Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland,

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Pentachlorophenol

Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### Picloram

Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

## Violations Table

---

### Simazine

---

Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.

---

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

---

## Monitoring Violations Annual Notice

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

#### Monitoring Requirements Not Met for the Village of Clifton

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 1/1/23 thru 12/31/25 we did not complete all monitoring for synthetic organic compounds and therefore cannot be sure of the quality of our drinking water during that time.*

#### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
SIMAZINE	THREE YEARS	ONE	2023 - 2025	03/26/2025
ENDRIN	THREE YEARS	ONE	2023 – 2025	03/26/2025
ETHYLENE DIBROMIDE	THREE YEARS	ONE	2023 – 2025	03/26/2025
HEPTACHLOR	THREE YEARS	ONE	2023 – 2025	03/26/2025
HEXACHLOROBE-NZENE	THREE YEARS	ONE	2023 – 2025	03/26/2025
LASSO	THREE YEARS	ONE	2023 – 2025	03/26/2025
METHOXYCHLOR	THREE YEARS	ONE	2023 – 2025	03/26/2025
OXAMYL	THREE YEARS	ONE	2023 – 2025	03/26/2025

## Monitoring Violations Annual Notice

PICLORAM	THREE YEARS	ONE	2023 – 2025	03/26/2025
ENDOTHALL	THREE YEARS	ONE	2023 – 2025	03/26/2025
TOTAL DDT	THREE YEARS	ONE	2023 - 2025	03/26/2025
<b>Contaminant</b>	<b>Required sampling frequency</b>	<b>Number of samples taken</b>	<b>When all samples should have been taken</b>	<b>When samples were taken</b>
TOTAL POLYCHLORINATED BIPHENYLS (PCP)	THREE YEARS	ONE	2023 – 2025	03/26/2025
HEPTACHLOR EPOXIDE	THREE YEARS	ONE	2023 – 2025	03/26/2025
PENTACHLOROPHENOL	THREE YEARS	ONE	2023 – 2025	03/26/2025
BENZO(A)PYRENE	THREE YEARS	ONE	2023 – 2025	03/26/2025
DIQUAT	THREE YEARS	ONE	2023 – 2025	03/26/2025
HEXACHLOROCYCLOPENTADIENE	THREE YEARS	ONE	2023 – 2025	03/26/2025
2,4,5-TP	THREE YEARS	ONE	2023 – 2025	03/26/2025
2,4-D	THREE YEARS	ONE	2023 – 2025	03/26/2025
ATRAZINE	THREE YEARS	ONE	2023 – 2025	03/26/2025
BHC-GAMMA	THREE YEARS	ONE	2023 – 2025	03/26/2025
CARBOFURAN	THREE YEARS	ONE	2023 – 2025	03/26/2025
DI(2-ETHYLHEXYL) PHTHALATE	THREE YEARS	ONE	2023 – 2025	03/26/2025
DINOSEB	THREE YEARS	ONE	2023 – 2025	03/26/2025
DALAPON	THREE YEARS	ONE	2023 – 2025	03/26/2025

## Monitoring Violations Annual Notice

1,2-DIBROMO-3-CHLOROPROPANE	THREE YEARS	ONE	2023 – 2025	03/26/2025
DIELDRIN	THREE YEARS	ONE	2023 – 2025	03/26/2025
DI(2-ETHYLHEXYL) ADIPATE	THREE YEARS	ONE	2023 – 2025	03/26/2025
CHLORDANE	THREE YEARS	ONE	2023 – 2025	03/26/2025
ALDRIN	THREE YEARS	ONE	2023 - 2025	03/26/2025

### What happened? What is being done?

The Village of Clifton was required to collect and submit water sample results for the contaminants listed in this notice by 1/12/26. The required samples were collected on time and analyzed within the required compliance period. The laboratory results showed that all contaminant levels were within allowable standards.

However, the violation occurred because the certified laboratory submitted the analytical results to the IEPA on 1/27/26, which was after the required reporting deadline of 1/12/26.

Although this situation affected all customers of the Village of Clifton water system, there is no indication that our drinking water poses a health risk, since the test results were within regulatory limits.

Monitoring and reporting requirements are in place to ensure that drinking water meets all safety standards.

To return to compliance, we collected and resubmitted the required water samples on 2/26/26. We expect to receive confirmation from the IEPA that we are back in compliance by 3/17/26.

We have contacted the laboratory about how to possibly prevent this from happening again.

For more information, please contact Dean Hartman at (815) 954-1822 or P.O. Box 472, Clifton, IL 60927.

## Monitoring Violations Annual Notice

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the  
Village  
Of Clifton.

Water  
System ID#

0750250

Date  
distributed

03/03/2026